

STATEMENT OF BASIS
CITY OF CENTRALIA
NPDES PERMIT NO. WA0020982

The purpose of this Statement of Basis is to explain the need to modify the Permit to clarify the effluent limits for Fecal Coliform.

I. GENERAL INFORMATION

- A. Permittee: City of Centralia
 1100 North Tower
 Centralia, Washington 98561
- B. Discharge Locations: Chehalis River Mile 66.8
 Latitude: 46° 45' 41" N
 Longitude: 123° 01' 38" W

II. REQUEST FOR MODIFICATION:

The final dry and wet weather effluent limits for fecal coliform were inadvertently listed as a daily maximum for the weekly average technology limit of 400 cfu/100 mL. The permit will be modified to change the daily maximum limit to a weekly average limit of 400 cfu/100 mL for fecal coliform.

This Statement of Basis will serve as an amendment to the Fact Sheet and Permit.